

---

# Declaration of Conformity

(according to ISO/IEC Guide 22 and EN 45014)

---

**Manufacturer's Name:** Integra Enclosures Inc.

**Manufacturer's Address:** 8989 Tyler Blvd.  
Mentor, Ohio 44060 U.S.A.

*declares that this product:*

**Product Name:** Integra Polycarbonate Electrical Enclosures, Standard Accessories & Packaging

**Integra polycarbonate enclosures meet or exceed the E.U. Directive. They are CE compliant and UL registered products.** Low Voltage Directives (73/23/EEC, 2006/95/EC & 2014/35/EU). Boxes and enclosures for electrical accessories for household and similar electrical installations – Part 1: General Requirements, EN 60670-1: 2005. Degrees of protection provided by enclosures (IP Code): IEC/EN 60529.

**Integra polycarbonate Cutout Enclosures, per UL listing E207562, are rated to meet or exceed:**

NEMA ratings; 1, 2, 3, 3R, 3S, 4, 4X, 12 & 13. For Integra "UL/CE-CUTOOUT BOX" (IP66) configurations.  
NEMA ratings; 1, 2, 3, 3R, 3S, 4, 4X, 6, 6P 12 & 13. For Integra "UL/CE P-SERIES" (IP68) configurations.  
In accordance with the Standard for Enclosures for Electrical Equipment, UL 50, 12th Edition and UL 50E, 1st Edition.  
In accordance with the CNL Canadian Standard C22.2 No. 94.1 and 94.2.

**Integra polycarbonate Junction and Pull Box Enclosures, per UL listing E229365 are rated to meet or exceed:**

NEMA ratings; 1, 2, 3, 3R, 3S, 4, 4X, 6, 6P 12 & 13. For Integra "UL/CE-JUNCTION" (IP68) configurations.  
In accordance with the Standard for Enclosures for Electrical Equipment, UL 50, 12th Edition and UL 50E, 1st Edition.  
In accordance with the CNL Canadian Standard C22.2 No. 94.1 and 94.2.

**Integra polycarbonate enclosures, standard accessories and packaging meet the European Council Directive 2015/863/ EU (RoHS 3) amendment of 2011/65/EU (RoHS 2) including Annex II; recasting 2002/95/EC (RoHS 1), on the Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment (RoHS).**

**Integra polycarbonate enclosures, standard accessories\* and packaging meet the European Chemicals Agency (ECHA) Regarding Regulation (EC) No. 1907/2006 concerning Registration, Evaluation, Authorization and Restriction of Chemicals (REACH 209 thru 6-25-2020).**

\*Exception - Integra non-metallic latches contain a flame retardant known as Dechlorane Plus (CAS no. 13560-89-9) in concentrations above 0.1% w/w. They are considered "articles" as defined by the legislation and do not involve the intentional release of this substance. Consequently, they are exempt from registration and/or pre-registration under REACH.

**Integra polycarbonate enclosures are intended for indoor or outdoor use and meet the highest outdoor rating for polycarbonate of f1 for UV resistance per UL 746C.**

## Supplementary Information

Notified Body: F-Squared Laboratories  
Report Number(s): F2LQ2599A-02S

Notified Body: Underwriters Laboratories Inc.  
Report Number(s): E207562, E229365 & E48746

Notified Body: Bureau Veritas Consumer Products Services Co., Ltd.  
Report Number(s): (9314)107-1312 & (9314)107-1313

Notified Body: SGS-CSTC Standards Technical Services Co., Ltd.  
Report Number(s): CANEC1823610401, CANEC1823611801, CANEC2018285901 & CANEC2018285902

On Behalf of Integra Enclosures Inc.  
Rich Palin



Engineering Manager  
MUM Industries (Integra/StrongBox)